

板坂地区

(放流水質)

令和4年度

月	pH	SS mg/ℓ	COD mg/ℓ		BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ		T-P mg/ℓ		大腸 個/mℓ
排水基準値	5.8-8.6	90 (70)	50 (40)		25 (20)		120 (60)		16 (8)		3000
4	7.4	3.0	23.0	26.0	12.0	31.0	31.0	33.0	2.90	3.30	1未満
5	7.3	2.0	19.0	21.0	9.9	31.0	26.0	29.0	2.50	3.00	1未満
6	7.2	2.0	23.0	23.0	7.3	35.0	33.0	33.0	3.00	3.10	1未満
7	7.4	3.0	22.0	19.0	6.8	40.0	34.0	29.0	3.30	2.70	1未満
8	7.2	5.0	23.0	22.0	15.0	37.0	35.0	32.0	3.80	3.00	1未満
9	7.0	3.0	17.0	13.0	3.4	35.0	26.0	25.0	2.50	2.50	13
10	7.4	1.0	17.0	17.0	5.2	32.0	29.0	27.0	2.80	2.40	1未満
11	7.4	3.0	18.0	21.0	5.4	35.0	33.0	33.0	3.00	2.90	1未満
12	7.2	3.0	18.0	21.0	3.3	32.0	30.0	31.0	2.80	2.70	1未満
1	7.4	5.0	27.0	23.0	6.2	42.0	41.0	32.0	3.40	2.80	1未満
2	7.5	2.0	25.0	22.0	7.0	40.0	33.0	34.0	3.20	3.20	1未満
3	7.5	6.0	23.0	24.0	8.5	37.0	33.0	33.0	2.90	3.00	2600
平均	7.3	3.2		21.1	7.5	35.6		31.5		2.95	237.3
最大	7.5	6.0		27.0	15.0	42.0		41.0		3.80	2600.0
最小	7	1.0		13.0	3.3	31.0		25.0		2.40	1.0

板坂地区

(流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.1	130.0	90.0	120.0	35.0	3.6
8	7.3	70.0	64.0	70.0	35.0	3.3
11	7.3	170.0	100.0	120.0	43.0	4.1
2	7.4	85.0	92.0	70.0	42.0	4.0
平均	7.3	113.8	86.5	95.0	38.8	3.8
最大	7.4	170.0	100.0	120.0	43.0	4.1
最小	7.1	70.0	64.0	70.0	35.0	3.3

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

鍛冶屋地区 (放流水質)

令和4年度

月	pH	SS mg/ℓ	COD mg/ℓ				BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ				T-P mg/ℓ				大腸 個/mℓ
排水基準値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				3000
4	7.4	3.0	29.0	31.0	27.0	26.0	14.0	38.0	33.0	32.0	34.0	32.0	3.40	3.40	3.40	3.10	1未満
5	7.4	1.0	23.0	31.0	25.0	26.0	10.0	35.0	29.0	35.0	29.0	34.0	2.90	3.40	3.00	3.30	1未満
6	7.4	3.0	26.0	24.0	23.0	22.0	12.0	36.0	33.0	32.0	30.0	33.0	3.30	3.20	3.00	3.20	1未満
7	7.5	1.0	22.0	24.0	23.0	19.0	8.5	41.0	30.0	32.0	29.0	26.0	3.20	2.90	3.00	2.70	1未満
8	7.5	2.0	19.0	21.0	20.0	18.0	6.8	37.0	27.0	25.0	29.0	26.0	2.90	2.80	3.20	2.80	1未満
9	7.5	2.0	17.0	17.0	17.0	18.0	4.7	32.0	24.0	26.0	23.0	28.0	2.50	2.90	2.60	3.00	1未満
10	7.5	2.0	18.0	17.0	20.0	19.0	4.8	37.0	26.0	24.0	26.0	28.0	2.70	2.50	2.70	3.10	1未満
11	7.5	2.0	21.0	20.0	21.0	23.0	4.3	39.0	29.0	29.0	27.0	28.0	3.20	3.10	2.90	3.00	1未満
12	7.3	3.0	21.0	25.0	23.0	24.0	9.8	35.0	28.0	30.0	28.0	30.0	2.80	3.00	2.90	2.90	1未満
1	7.5	2.0	31.0	35.0	32.0	32.0	10.0	43.0	36.0	34.0	31.0	32.0	3.30	3.40	3.20	3.30	1未満
2	7.6	2.0	33.0	35.0	34.0	33.0	18.0	40.0	32.0	30.0	33.0	33.0	3.40	3.10	3.50	3.30	1未満
3	7.5	3.0	33.0	35.0	31.0	31.0	13.0	37.0	32.0	32.0	31.0	28.0	3.20	3.30	3.10	2.90	1未満
平均	7.5	2.2					24.9	9.7	37.5				29.8			3.06	1.0
最大	7.6	3.0					35.0	18.0	43.0				36.0			3.50	1.0
最小	7.3	1.0					17.0	4.3	32.0				23.0			2.50	1.0

鍛冶屋地区 (流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.1	200.0	130.0	180.0	44.0	4.7
8	7.2	130.0	100.0	130.0	41.0	3.9
11	7.2	200.0	110.0	150.0	45.0	4.3
2	7.3	200.0	120.0	170.0	46.0	4.9
平均	7.2	182.5	115.0	157.5	44.0	4.5
最大	7.3	200.0	130.0	180.0	46.0	4.9
最小	7.1	130.0	100.0	130.0	41.0	3.9

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

余田地区

(放流水質)

令和4年度

月	pH	SS mg/ℓ	COD mg/ℓ				BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ				T-P mg/ℓ				大腸 個/mℓ
排水基準値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				3000
4	7.4	3.0	27.0	26.0	26.0	23.0	9.0	36.0	33.0	34.0	33.0	30.0	3.50	3.40	3.60	2.80	1未満
5	7.3	2.0	19.0	27.0	21.0	25.0	5.4	28.0	24.0	35.0	25.0	33.0	2.50	3.30	2.60	3.30	1未満
6	7.3	4.0	24.0	24.0	22.0	21.0	8.4	39.0	32.0	28.0	27.0	27.0	3.10	3.00	2.80	2.80	1未満
7	7.4	3.0	22.0	20.0	19.0	17.0	7.5	39.0	28.0	28.0	23.0	20.0	2.90	2.50	2.60	2.30	1未満
8	7.4	8.0	26.0	15.0	20.0	17.0	6.0	37.0	27.0	19.0	25.0	20.0	3.40	2.30	2.70	2.40	1未満
9	7.3	3.0	17.0	19.0	14.0	18.0	4.8	27.0	19.0	26.0	21.0	24.0	2.10	2.80	2.40	2.80	1未満
10	7.3	3.0	18.0	17.0	21.0	20.0	4.8	35.0	25.0	18.0	25.0	27.0	2.90	2.00	2.60	3.10	1未満
11	7.5	3.0	22.0	25.0	21.0	20.0	5.4	39.0	30.0	30.0	28.0	26.0	3.40	3.30	3.20	2.90	1未満
12	7.0	5.0	21.0	26.0	24.0	26.0	6.8	33.0	26.0	31.0	30.0	31.0	3.00	3.00	3.10	3.10	1未満
1	7.4	3.0	32.0	32.0	27.0	27.0	8.8	44.0	38.0	35.0	29.0	34.0	3.60	3.50	2.90	3.50	1未満
2	7.6	2.0	28.0	28.0	27.0	30.0	8.6	43.0	34.0	30.0	33.0	33.0	3.60	3.00	3.40	3.30	1未満
3	7.5	2.0	31.0	34.0	30.0	30.0	9.9	38.0	34.0	35.0	31.0	31.0	3.60	3.50	3.10	2.40	1未満
平均	7.4	3.4					23.5	7.1	36.5				28.4			2.98	1.0
最大	7.6	8.0					34.0	9.9	44.0				38.0			3.60	1.0
最小	7	2.0					14.0	4.8	27.0				18.0			2.00	1.0

余田地区

(流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.2	120.0	93.0	110.0	36.0	3.9
8	7.1	110.0	68.0	70.0	32.0	3.4
11	7.3	66.0	68.0	66.0	43.0	3.8
2	7.4	160.0	110.0	120.0	43.0	4.8
平均	7.3	114.0	84.8	91.5	38.5	4.0
最大	7.4	160.0	110.0	120.0	43.0	4.8
最小	7.1	66.0	68.0	66.0	32.0	3.4

放流基準値

pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

大貫地区 (放流水質)

令和4年度

月	pH	SS mg/ℓ	COD mg/ℓ				BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ				T-P mg/ℓ			大腸 個/mℓ	
排水基準値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)			3000	
4	7.3	3.0	25.0	26.0	25.0	21.0	15.0	33.0	32.0	29.0	28.0	24.0	3.30	3.30	3.30	2.80	1未満
5	7.3	3.0	21.0	24.0	20.0	21.0	6.9	31.0	23.0	25.0	20.0	22.0	2.90	3.30	2.70	3.10	1未満
6	7.1	4.0	22.0	20.0	21.0	19.0	14.0	34.0	21.0	21.0	19.0	18.0	3.00	3.30	3.10	3.10	1未満
7	7.2	3.0	19.0	19.0	18.0	19.0	6.3	36.0	20.0	19.0	16.0	14.0	3.30	2.90	2.70	2.90	1未満
8	7.1	3.0	22.0	16.0	18.0	17.0	4.9	33.0	14.0	14.0	17.0	14.0	3.00	2.70	2.90	2.70	1未満
9	7.2	3.0	18.0	18.0	16.0	18.0	6.4	30.0	13.0	13.0	10.0	13.0	2.60	2.70	2.20	2.90	1未満
10	7.0	4.0	18.0	16.0	20.0	20.0	5.4	33.0	12.0	11.0	13.0	13.0	2.60	2.30	2.60	3.00	1未満
11	7.3	3.0	21.0	20.0	19.0	19.0	1.4	34.0	22.0	24.0	21.0	22.0	3.10	3.00	2.70	2.90	1未満
12	7.3	4.0	20.0	20.0	21.0	25.0	4.1	32.0	22.0	24.0	21.0	26.0	2.90	2.90	2.60	2.80	1未満
1	7.4	2.0	26.0	25.0	24.0	26.0	7.0	40.0	31.0	28.0	25.0	27.0	3.10	3.10	2.80	3.10	1未満
2	7.5	2.0	25.0	24.0	26.0	25.0	6.5	35.0	27.0	27.0	27.0	27.0	3.10	2.90	3.00	2.90	1未満
3	7.4	2.0	25.0	27.0	25.0	19.0	6.0	35.0	28.0	29.0	27.0	24.0	3.00	3.20	2.90	2.80	1未満
平均	7.3	3.0					21.2	7.0	33.8				21.2			2.92	1.0
最大	7.5	4.0					27.0	15.0	40.0				32.0			3.30	1.0
最小	7	2.0					16.0	1.4	30.0				10.0			2.20	1.0

大貫地区 (流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.1	140.0	110.0	140.0	38.0	4.3
8	7.1	93.0	80.0	74.0	35.0	3.5
11	7.2	150.0	110.0	110.0	51.0	5.1
2	7.3	89.0	91.0	88.0	49.0	4.6
平均	7.2	118.0	97.8	103.0	43.3	4.4
最大	7.3	150.0	110.0	140.0	51.0	5.1
最小	7.1	89.0	80.0	74.0	35.0	3.5

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

田口地区

(放流水質)

令和4年

月	pH	SS mg/ℓ	COD mg/ℓ		BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ		T-P mg/ℓ		大腸 個/mℓ
排水基準値	5.8- 8.6	90 (70)	50 (40)		25 (20)		120 (60)		16 (8)		3000
4	6.6	3.0	7.3	7.3	2.0	36.0	5.1	5.1	3.60	3.50	1未満
5	6.7	2.0	7.8	7.9	2.5	36.0	4.5	4.3	2.80	2.90	1未満
6	6.7	4.0	8.3	6.7	2.7	34.0	5.7	4.7	3.30	2.70	1未満
7	6.8	2.0	6.2	6.6	3.1	39.0	4.3	3.5	2.90	3.50	1未満
8	6.8	3.0	6.3	7.6	1.4	36.0	5.1	3.8	2.70	3.20	1未満
9	7.0	6.0	7.7	6.6	3.2	33.0	4.5	4.5	2.60	2.90	1未満
10	6.8	3.0	6.9	6.7	1.8	38.0	6.5	5.1	4.60	2.80	1未満
11	6.7	2.0	7.3	6.8	1.2	34.0	8.9	5.2	4.10	3.00	1未満
12	7.0	2.0	7.4	6.7	1.4	33.0	6.0	6.4	2.90	3.00	1未満
1	6.6	5.0	8.8	8.0	3.0	42.0	7.1	4.3	2.10	2.50	1未満
2	6.9	2.0	7.3	8.1	2.0	37.0	5.6	5.9	2.80	3.20	1未満
3	6.7	3.0	7.8	9.5	2.4	35.0	4.9	4.6	3.50	2.80	1未満
平均	6.8	3.1		7.4	2.2	36.1		5.2		3.08	1.0
最大	7.0	6.0		9.5	3.2	42.0		8.9		4.60	1.0
最小	6.6	2.0		6.2	1.2	33.0		3.5		2.10	1.0

田口地区

(流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.3	75	72.0	80.0	47.0	3.9
8	7.1	150	100.0	140.0	41.0	4.3
11	7.3	56	69.0	67.0	40.0	3.9
2	7.3	57	85.0	84.0	43.0	3.9
平均	7.3	85	81.5	92.8	42.8	4.0
最大	7.3	150	100.0	140.0	47.0	4.3
最小	7.1	56	69.0	67.0	40.0	3.9

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ

八千種地区

(放流水質)

令和4年度

月	pH	SS mg/ℓ	COD mg/ℓ				BOD mg/ℓ	Cl ⁻ mg/ℓ	T-N mg/ℓ				T-P mg/ℓ				大腸 個/mℓ	
排水基準 値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				3000	
4	6.7	6.0	9.0	9.2	8.7	16.0	5.9	37.0	2.0	2.6	2.7	3.5	2.90	2.80	2.70	2.50	1700	
5	6.7	5.0	7.9	9.1	7.4	8.8	6.4	29.0	1.6	2.8	2.1	2.8	1.80	2.40	1.70	2.40	1未満	
6	6.7	6.0	12.0	7.4	8.6	7.9	7.8	34.0	3.7	2.4	2.5	2.4	2.70	2.30	2.30	2.20	2100	
7	6.9	9.0	7.1	8.7	12.0	6.9	8.6	38.0	3.0	3.1	3.4	2.1	2.30	1.80	2.10	1.80	700	
8	6.9	5.0	7.6	7.6	9.8	8.6	2.6	41.0	2.3	2.4	5.9	2.4	2.20	2.00	2.20	2.00	1未満	
9	6.9	5.0	7.3	7.8	7.8	7.0	3.1	28.0	1.9	2.6	2.0	2.4	1.70	2.10	1.90	2.20	1未満	
10	6.9	4.0	7.1	7.8	6.7	7.8	3.2	36.0	1.9	1.6	1.8	2.4	2.20	1.90	2.10	2.80	1未満	
11	6.8	3.0	7.6	7.1	7.6	8.1	2.8	38.0	2.2	2.1	1.8	2.1	2.40	2.30	2.20	2.20	1未満	
12	6.8	9.0	8.6	9.2	9.1	7.4	3.8	34.0	2.4	2.5	1.9	2.1	2.10	2.30	2.20	2.30	1未満	
1	6.8	6.0	7.9	8.3	8.8	10.0	4.4	44.0	2.5	1.8	2.0	1.9	2.20	2.10	2.20	2.20	1未満	
2	6.9	3.0	7.3	7.5	8.0	7.0	3.0	41.0	2.1	2.0	2.3	2.3	2.40	2.30	2.60	2.40	1未満	
3	6.8	2.0	6.6	7.4	6.9	6.7	3.1	38.0	2.1	2.1	1.9	2.3	2.40	2.40	2.10	2.00	1未満	
平均	6.8	5.3					8.3	4.6	36.5				2.4				2.24	375.8
最大	6.9	9.0					16.0	8.6	44.0				5.9				2.90	2100.0
最小	6.7	2.0					6.6	2.6	28.0				1.6				1.70	1.0

八千種

(流入水質)

月	pH	SS mg/ℓ	COD mg/ℓ	BOD mg/ℓ	T-N mg/ℓ	T-P mg/ℓ
5	7.1	130.0	87.0	160.0	39.0	3.8
8	7.1	140.0	94.0	130.0	36.0	3.9
11	7.2	150.0	110.0	130.0	42.0	4.4
2	7.3	82.0	89.0	91.0	42.0	4.0
平均	7.2	125.5	95.0	127.8	39.8	4.0
最大	7.3	150.0	110.0	160.0	42.0	4.4
最小	7.1	82.0	87.0	91.0	36.0	3.8

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/ℓ
COD	40以下	mg/ℓ
BOD	20以下	mg/ℓ
Cl ⁻	—	mg/ℓ
T-N	60以下	mg/ℓ
T-P	8以下	mg/ℓ
大腸菌群数	3000以下	個/mℓ